

## **PURCHASE ENQUIRY**

Inquiry No : AFD/PUR/PKS/ENQ/AHU, Dated: Oct 22, 2016

**Description**: Purchase Inquiry for Supply, installation and commissioning of AHU.

Qty : As per Annexure -I.

**Due Date** : 29<sup>th</sup> Oct, 2016

## Dear Sir,

You are requested to give your most competitive rates for Supply, Installation and Commissioning of AHU our ongoing project at AmulFed Dairy at Gandhinagar with all necessary accessories required, as per the annexure attached herewith:

The offer should reach, AmulFed Dairy (A Unit Of Gujarat Co - Operative Milk Marketing Federation Limited.) Plot No. - 35, Near Indira Bridge, Ahmedabad - Gandhinagar Highway, Village: Bhat, Dist.: Gandhinagar. Pin No.382 428.

- The offer should be sent in sealed cover super scribing on the top left hand corner offer for inquiry No. AFD/PUR/PKS/ENQ/AHU dtd. 22/10/2016. Offer received after due date for whatsoever reason may be rejected.
- Your offer should be sent through Post/Courier/mail & not by Fax or personally.
- Offer should be valid for acceptance, for 60 days from due date of submission of offer.
- The price should be quoted on F.O.R basis inclusive of packing and forwarding, taxes, excise duties, freight etc. However if it is separate, it should be clearly mentioned in the quotation as per the attached annexure.
- It should cover a warranty of at least one-year against manufacturing defect from commissioning of the plant.
- Realistic earliest delivery period should be indicated.
- It is not binding on us to accept lowest offer.
- Right to reject any or all the offers without assigning any reason is reserved by us.
- Offer which are incomplete or not meeting the conditions or only for part items, are liable for rejections.
- No queries regarding the status of the offer will be entertained at any time.
- The final supplier will be the combined decision of our technical team and management and no reason of final selection will be conveyed to any bidder.
- Payment terms with 30 days credit shall be preferred.
- We are an ISO 14001 certified unit. We follow Eco- friendly processes in our factory & also expect same to be followed in your company.
- Contact detail: Mr. Palak Shah, Mail: palak.shah@amul.coop, Mob: 7359001666



## (PREVIOUSLY KNOWN AS MOTHER DAIRY, GANDHINAGAR) Annexure-I

Technical Requirement Specification of Pizza Deep Freezer AHU			
SN	Description	Capacity / Technical details	Remarks
1	Product Type	Ceiling mounted	
2	No of units	1	
3	Design duty continuous	24.5 kw (7 TR)	21000 Kacl /Hr
	heavy duty		
4	Fan type	Axial	
4	Coil MOC	S S 304 tubes with	Price for SS fins also
		Aluminium/ SS fins	should be provided
5	Room Temperature	-20 Deg C	
6	Refrigerant ( Ammonia )	-30 deg C (Overfeed)	Or Manufacture to
	Evaporating Temperature		provide
7	Refrigerant Flow	Manufacturer to provide	Or Manufacturer to
	/Refrigerent		provide
7	Casing	S S 304	SS price should also be
			provided
8	Unit dimension	Manufacturer to provide	Manufacturer to
		·	provide
9	No of Fans	2 Nos	
9	Air flow of each Fan	As per design/Manufacturer	As per
		to provide	design/Manufacturer to
			provide
11	Fins per inch (FPI)	10 mm FPI	Or Manufacturer to
			provide
12	Effective Heat transfer area	As per design/Manufacturer	As per
	(HTA)	to provide	design/Manufacturer to
			provide
13	Fan motor KW	As per design/Manufacturer	Manufacturer to
		to provide	provide
14	Complete technical	As per design/Manufacturer	Manufacturer to
	information	to provide	provide