



(Previously Known as Mother Dairy, Gandhinagar)

## Request for Quotation (RFQ)

AFD: PUR: HSG: IBR work for HP steam

17 May, 2023

To,

Dear Sir,

Sub: **Request for Quotation (RFQ)** for “IBR Work for HP steam” as mentioned in annexure.

- (1) **Shifting of HP steam line size DN150 (with steam flow meter and bypass line) from the existing HP steam line location to nearby location**
- (2) **Shifting of HP PRV station from existing first floor level to ground level**
- (3) **Fabrication and Installation of DPT (Drum Pressure Transmitter) unit with piping at 10 TPH Boiler Installation, Testing and Commissioning as per IBR Rules & Regulations. Details mentioned in annexure.**

We invite your most competitive offer for **above mentioned** as per detailed specifications. Your offer should be based on following considerations:

1. The offer should reach:-AmulFed Dairy (Previously known as Mother Dairy-A Unit Of GCMMF Ltd) Plot No-35, Nr. Indira Bridge, Ahmedabad - Gandhinagar Highway. Village Bhat, Dist - Gandhinagar. Pin - 382 424.

2. Due Date: **May 24, 2023 before 17:00 hours**

3. The offer should be submitted in portal only. First of all register your firm on shared link.

4. Offer received after due date for whatsoever reason may be rejected.

5. Offer should valid for acceptance for 90 days from date for submission of offer.

6. The price should be quoted with all details.

7. **Specify your tax condition.** Non indication of above levies will mean that prices are inclusive of all taxes and above levies.

8. Realistic and earliest completion period should be indicated in offer.

9. It will not be binding on us to accept the lowest offer.

10. Right to accept/reject any/all offers without assigning reason is reserved by us.

11. Offers which are incomplete or not meeting the conditions are liable for rejection.

12. Payment terms within 30 days of invoice receipt. If the payment term is document through bank, all banking charges shall be borne by the suppliers.

Plot No. 35, Nr. Indira Bridge, Ahmedabad-Gandhinagar Highway, Village: Bhat, Dist.:Gandhinagar, PIN 382428

Tel. No. (+91-79) 23969055 – 58, Fax No. (+91-79) 23969059

Website: www.amul.com

# AmulFed Dairy

A UNIT OF GUJARAT CO-OPERATIVE MILK MARKETING FEDERATION LIMITED

(Previously Known as Mother Dairy, Gandhinagar)

13. **Please find below link to register your firm on Purchase Portal. Without completing registration process on portal can't submit offer.**

**First of all register your firm on shared link so can send inquiry through portal only.**

Interested bidders have to register your firm in our Purchase portal.

Website for our portal is as >>>: <http://afdpurchase.amul.in/>

Click Below links for Guidelines :

1. [Guide for VRF - MANUFACTURERS](#)

14. **Eligibility criteria: Must have executed similar type of order.**

15. **Once registration process completes, we invite vendor to submit offer.**

We are an ISO 9001: 2008, ISO 14001:2004 and ISO 22000:2005 company; we follow sustainable eco-friendly processes in our organization and expect the same to be followed at your end. We emphasis on energy efficient system and utilization of renewable energy systems in eco friendly and sustainable way.

Note: If required please visit premises with prior confirmation before quote. Please arrange visit between 2:00 P.M. to 5:00 P.M. in working day.

: We may go for reverse auction/negotiation. If required we may ask for PBG.

Mail id as mentioned below.

Shri Hardik Gajjar : [hardik.gajjar@amul.coop](mailto:hardik.gajjar@amul.coop)

Shri Bharat Naik : [bharat.naik@amul.coop](mailto:bharat.naik@amul.coop)

Shri Prashant Sheth: [prashant.sheth@amul.coop](mailto:prashant.sheth@amul.coop)

Yours Faithfully,

For AmulFed Dairy,

Purchase Depart.

# AmulFed Dairy

A UNIT OF GUJARAT CO-OPERATIVE MILK MARKETING FEDERATION LIMITED

(Previously Known as Mother Dairy, Gandhinagar)

## Annexure – Removal and shifting of existing steam pipe lines

The job covers “Removal and shifting of existing steam pipe lines and Fabrication and Installation of DPT unit with piping at 10 TPH Boiler, Installation, Testing and Commissioning as per IBR Rules”. Details of existing economizer are as under:

Boiler Capacity	:	10 Ton per Hour
Fuel	:	Natural Gas /LDO / Bio Gas
Steam Pressure	:	17.5 Kg/ cm <sup>2</sup>
Max. Allowable working pressure	:	20 Kg/ cm <sup>2</sup>
Hydraulic Test pressure	:	33 Kg/ cm <sup>2</sup>
Max. Allowable working Temperature	:	215-250°C
Pipe size	:	150.0 mm x 3.4mmthickness

Drawing, MOC and dimensions of HP Steam and its pressure parts is attached herewith for further reference.

### **ELIGIBILITY OF CONTRACTOR**

Contractor should be IBR Approved as per IBR Rules & Regulation either Boiler manufacturer with their own design institute to carry out the study of boiler combustion and design of boiler.

OR

Contractor must have associated with the renowned steel manufacturer for the manufacturing of the pressure parts along with the technological partnership with the design institute where the study of combustion optimization and design of boiler can be done.

Contractor must have experience in Engineering, Design and manufacturing and performance testing of the boiler.

Plot No. 35, Nr. Indira Bridge, Ahmedabad-Gandhinagar Highway, Village: Bhat, Dist.:Gandhinagar, PIN 382428  
Tel. No. (+91-79) 23969055 – 58, Fax No. (+91-79) 23969059  
Website: www.amul.com



(Previously Known as Mother Dairy, Gandhinagar)

Contractor must have executed similar kind of work

## **2. SCOPE OF WORK**

Scope of work covers for removal and shifting of existing **“removal and shifting of existing steam pipe lines and Fabrication and Installation of DPT unit with piping at 10 TPH Boiler, Installation, Testing and Commissioning as per IBR Rules”** (Including Radiography Testing, Hydraulic Testing, Material Inspection at Site, etc).

- 2.1 Contractor has to visit actual site conditions for removal and shifting of existing **“removal and shifting of existing steam pipe lines and Fabrication and Installation of DPT unit with piping at 10 TPH Boiler, Installation, Testing and Commissioning as per IBR Rules”**.
- 2.2 Providing required man power including supervision, and all the required Tools & Plants including all suitable lifting shifting material
- 2.3 Receipt & unloading of Material/equipment as stated above, pertaining to erection and commissioning of economizer coil.
- 2.5 The contractor shall strictly abide by the state and central laws, IBR rules, regulations etc. In addition, the contractor shall have to comply with safety requirements are the responsibility of the contractor.

## **3. TIMESCHEDULE**

- 3.1 Submission of drawing and repair / replace permission at boiler office within 10 days from the date of issue of Purchase Order.
- 3.2 Obtaining IBR approval for repairing/replacing of economizer within a week of submission of permission.
- 3.3 Supply and installation of economizer coil.
- 3.4 Carryout IBR inspection and testing at site and obtaining final approval for starting of economizer.

# AmulFed Dairy

A UNIT OF GUJARAT CO-OPERATIVE MILK MARKETING FEDERATION LIMITED

(Previously Known as Mother Dairy, Gandhinagar)

On Letter Head of Vendor / Customer.

To,  
General Manager  
AmulFed Dairy (A Unit of GCMF Ltd.)  
Village:- Bhat,  
Near Indira Bridge,  
Gandhinagar-382 428

Dear Sir,

**Sub : Fund Transfer Payments.**

I/we request and authorise you to effect Fund Transfer Payment to my / our Bank account as per the details given below (Please map our account in your SAP):

Vendor Name:- : \_\_\_\_\_  
Vendor Code : \_\_\_\_\_  
Bank Account Name : \_\_\_\_\_  
Bank Account Number : \_\_\_\_\_  
Branch Name & Address of Bank: \_\_\_\_\_  
Email Id : \_\_\_\_\_  
Permanent A/c Number (PAN) : \_\_\_\_\_  
Name of the Auth signatory : \_\_\_\_\_  
Contact Person : \_\_\_\_\_  
Contact Number : \_\_\_\_\_  
IFSC code : \_\_\_\_\_  
MICR Code : \_\_\_\_\_  
Type of Account : Savings / Current / Cash Credit

I, hereby declare that the particulars given above are correct. If the transaction is delayed or not effected at all for reasons of incomplete or incorrect information, I would not hold the user institution responsible. I hereby authorise Bank ( as mentioned above) to credit my above mentioned account with the amount of instalment and I agree to discharge the responsibility expected of me as a participant under the scheme.

Date: \_\_\_\_\_

Signature of Account Holder (s)

- Mandatory fields -cannot be left blank.
  - Kindly attach a blank cancelled cheque with this mandate form.

---

**Bankers Attestation -**

**CERTIFIED THAT THE PARTICULARS FURNISHED ABOVE ARE CORRECT AS PER OUR RECORDS.**

BANK STAMP

DATE : \_\_\_\_\_

\_\_\_\_\_  
SIGNATURE OF BANK OFFICIAL

Plot No. 35, Nr. Indira Bridge, Ahmedabad-Gandhinagar Highway, Village: Bhat, Dist.:Gandhinagar, PIN 382428  
Tel. No. (+91-79) 23969055 – 58, Fax No. (+91-79) 23969059  
Website: www.amul.com