



AmulFed Dairy

A UNIT OF GUJARAT CO-OPERATIVE MILK MARKETING FEDERATION LIMITED

(PREVIOUSLY KNOWN AS MOTHER DAIRY, GANDHINAGAR)

PURCHASE ENQUIRY

AFD: PUR: APPR: 2020: 188

14.10.2020

Dear Sir,

We would like to invite you for most competitive rates for supply of Air shower unit as per details given in annexure –I.

Terms & Condition:

- 1) The offer should reach on email dweej.shah@amul.coop before due date.
- 2) Due Date: 26.10.2020
- 3) The offer should be send in e mail to before due date.
- 4) Offer received after due date for whatsoever reason may be rejected.
- 5) Offer should be valid for acceptance for 90 days.
- 6) The Rates / price should be for F.O.R. destination basis inclusive of packing & forwarding and freight. However it should be clearly mentioned in the quotation.
- 7) F.O.R. Destination is:

AmulFed Dairy (Prev. Known as mother dairy)
Packaging Film plant-gandhinagar
Sector-25,K Road, GIDC,
382044 Gandhinagar
GSTIN:- 24AAAAG5588Q1Z2
- 8) Your Rates should as per annexure – I.
- 9) It is not binding on us to accept lowest offer.
- 10) Right to reject any or all the offers without assigning any reason is reserved by us.
- 11) Offer which are incomplete or not meeting the condition/our requirement or only for part items, are liable for rejections.
- 12) Management reserves the rights to accept or reject all/any offers submitted by bidders, without assigning any reasons. In case of any dispute Management decision in these regards would be considered as final and no complaints will be entertained. For Legal dispute, Ahmedabad shall jurisdiction.
- 13) Payment Terms within 30 days after supply should be accepted.

Thanking you,

For AmulFed Dairy, Gandhinagar

Purchase Department



AmulFed Dairy

A UNIT OF GUJARAT CO-OPERATIVE MILK MARKETING FEDERATION LIMITED
(PREVIOUSLY KNOWN AS MOTHER DAIRY, GANDHINAGAR)

Annexure – I

Supply of Paper core cutter machine Rate Sheet

| Sr. No. | Details | Qty | UoM | Offered Rate for Supply (Basic - Rs.) for 1 Ea | GST % |
|---------|-----------------|-----|-----|--|-------|
| 1 | Air Shower Unit | 2 | Ea | | |

| DESCRIPTION | SPECIFICATION |
|-------------------------------|---|
| PERSON ENTRY CAPACITY | 2 PERSON |
| SUCTION FILTER | 4 PRIMARY PRE FILTER(WASHABLE FILTER MEDIA) AND 4 HEPA FILTER LESS THAN 0.3 MICRON(99% EFFICIENCY) |
| NOZZLE FOR AIR SHOWRING | AIR SHOWERING NOZZLE -32 NOS (14-14 NOZZLE EACH AND 4 NOZZLE AT TOP) |
| BLOWER UNIT | CONTAIN 8 NUMBER OF ALUMINIUM IMPELLER BLOWER WITH 4 NUMBER OF 3 PHASE MOTOR |
| OPERATION AND CONTROL OF UNIT | MICROPROCESSOR CONTROL, FULLY AUTOMATIC OPERATION |
| EMERGENCY EXIT | EMERGENCY SWITCH INSIDE |
| NOISE LEVEL | LESS THAN 65 DB |
| TYPE | Mist shower |
| MOC | SS -304/SS -315/ Customized |
| FLOW | From two sides |
| Velocity at Nozzel | 25-30 MPS |
| Air cleanliness | ISO class -5 |
| HEPA filter | Hepa filters which confirms to H13/H14 with efficiency of 99.997% down to 0.3 micron |
| DOOR | SS -304 double watch sandwich panel with toughened view glass |
| Interlocking | Interlocking between the doors by electrogomagnetic locks |
| Light/Switches | fluoroscent light on and off switches for blower and lights |
| Vibration level | minimum |
| Power supply | 220-230 V AC /three phase/ 50 Hz |

Sign and Stamps of Bidder/Supplier on Each page require.