



AMULFED DAIRY

A UNIT OF GUJARAT CO-OPERATIVE MILK MARKETING FEDERATION LIMITED
PURCHASE ENQUIRY

Inquiry No : AFD: PUR: ENQ: 2021: 864, Dated: Oct 25, 2021
Description : Repairing of Catta Cone Hardening Tuneel.
Qty : 1 Job
Due Date : 10th Nov, 2021
Plant Visit : All bidders are requested to visit AFD before submitting offer.
Timing for Visit: 2.30 pm to 5.00 pm (except Sunday and public holidays) from
26.1.2021 to 9.11.2021

Dear Sir,

You are requested to give your most competitive rates for Repairing of Hardening Tuneel as per the technical specification mentioned below:

The offer should reach, AmulFed Dairy (A Unit Of Gujarat Co - Operative Milk Marketing Federation Limited.) Plot No. - 35, Near Indira Bridge, Ahmedabad - Gandhinagar Highway, Village: Bhat, Dist.: Gandhinagar. Pin No.382 428 **within above give due date in Hardcopy.**

The offer should be sent in sealed cover super scribing on the top left hand corner offer for inquiry No. AFD: PUR: ENQ: 2021: 864, dtd. 25/10/21. Offer received after due date for whatsoever reason may be rejected.

- Offer should be valid for acceptance, for 45 days from due date of submission of offer.
- The price should be quoted on F.O.R basis inclusive of packing and forwarding, freight etc. However it should be clearly mentioned in the quotation as per enclosed format only.
- Price should be inclusive of all the taxes, excise duties etc., or it should be mentioned separately in your offer clearly. It should cover a warranty of at least one-year against manufacturing defect.
- Realistic earliest delivery period should be indicated.
- It is not binding on us to accept lowest offer.
- Right to reject any or all the offers without assigning any reason is reserved by us.
- Offer which are incomplete or not meeting the conditions or only for part items, may liable for rejections.
- No queries regarding the status of the offer will be entertained at any time.
- The final supplier will be the combined decision of our technical team and management and no reason of final selection will be conveyed to any bidder.
- Payment terms with 30 days credit shall be preferred.
- For any query contact Mr. Palak Shah of Purchase dept.(07359001666) or mail on: palak.shah@amul.coop

Amul SAGAR

Plot No. 35, Nr. India Bridge, Ahmedabad – Gandhinagar Highway, Village: Bhat, Dist.: Gandhinagar, PIN 382 428
Tel. No.: (079) 23969055 – 58, Fax No.: (079) 23969059
Website: www.amul.com



AMULFED DAIRY

A UNIT OF GUJARAT CO-OPERATIVE MILK MARKETING FEDERATION LIMITED

Technical Specification

Repairing Work of Catta Cone Machine (Old):

PRE FAB PANELS FOR 150 MM COLD ROOM

1. Cold Room Outer Size (Ft) : 9'-8" X 22' 1.5" X 12'-1" - (W X D X H)
2. Cold Room Outer Size (Inch) : 116" X 265.5" X 145" - (W X D X H)
3. Total Storage Volume: 2000 C.F.T
4. Panel Construction: Prefabricated sandwich PUF panels with Panel to Panel Cam lock joints & PVC gasket. Panel with grooves to increase the strength.
5. Panel Thickness: 150 mm. PUF (poly urethane foam), Density 40 + 2 Kg / m3 Puf
6. Blowing agent-Hydro Carbon CycloPentane (CFC/HCFC/HFC free)
7. Panel Surface Material: 150 mm. Puf Panel Bothside SS 304 2B, Sheet Thickness 0.5mm.
8. Floor Insulation: Floor Puf Slab with both side SS 304 with higher density which can hold 4 tons of point load of AHU and conveying system support Tarfelt for Kota stone.
9. Door Accessories: Flush type Swing Door with Heavy duty Imported Hardware like Hinges, Handle & Door closer. Door frame made in Heavy duty PVC profile within built heater arrangement to remove defrosting on door & Push type. The temperature of Hardening tunnel will be minus 40 deg C.
10. Gasket to stop air lose & easy operation for Long life.
11. Door Opening size, Nos & MOC: Door opening size: 34" x 78" (W x H) - 1 Nos. (With Heater)- Bothside SS304 2B. 0.5 mm.
12. Light: Vapor proof Bulk head provide proper lighting in each & every corner of the cold room.
13. Pressure Relief port: Pressure relief port to balance the air pressure within the room to reduce damage of panel due to vacuum.
14. Kick Plate: SS304 Plain Plate on bothside of Door bottom to reduce damage.
15. Safety Release Knob: Safety release Knob placed at the inner side of the door for safety precautions.

- Note:
1. Material provided should with stand temp. Minus 40 Deg C.
 2. Removal of Old panels in scope of Supplier.
 3. Supplier should bring all the tools and tackles with them necessary for execution of the order.
 4. Supplier should visit the site before quoting so as to understand the scope of work.

All the Bidders have to provide their best competitive rates on Buy Back offer basis. All the bidders have taken back old panels with related accessories from AFD.

Amul SAGAR

Plot No. 35, Nr. India Bridge, Ahmedabad – Gandhinagar Highway, Village: Bhat, Dist.: Gandhinagar, PIN 382 428
Tel. No.: (079) 23969055 – 58, Fax No.: (079) 23969059
Website: www.amul.com