



(Previously Known as Mother Dairy, Gandhinagar)

Request for Quotation (RFQ)

AFD: PUR: HSG: HT LT Cables laying.

29 Oct., 2024

To,

Dear Sir,

Sub: **Request for Quotation (RFQ)** for “HT/LT cables laying as per annexure” as mentioned in annexure.

We invite your most competitive offer for **HT/LT cables laying as per annexure** as per detailed specifications. Your offer should be based on following considerations:

1. The offer should reach:-AmulFed Dairy (Previously known as Mother Dairy-A Unit Of GCMMF Ltd) Plot No-35, Nr. Indira Bridge, Ahmedabad - Gandhinagar Highway. Village Bhat, Dist - Gandhinagar. Pin - 382 424.

2. Due Date: **Technical due November 09, 2024 before 14:00 hours.**

Commercial due November 11, 2024 before 17:00 hours.

3. The offer should be submitted in portal only. First of all register your firm on shared link.

4. Offer received after due date for whatsoever reason may be rejected.

5. Offer should valid for acceptance for 90 days from date for submission of offer.

6. The price should be quoted with all details.

7. **Specify your tax condition.** Non indication of above levies will mean that prices are inclusive of all taxes and above levies.

8. Realistic and earliest completion period should be indicated in offer.

9. It will not be binding on us to accept the lowest offer.

10. Right to accept/reject any/all offers without assigning reason is reserved by us.

11. Offers which are incomplete or not meeting the conditions are liable for rejection.

12. Payment terms after successful installation and testing of laid HT LT cables within 30 days of invoice receipt. If the payment term is document through bank, all banking charges shall be borne by the suppliers.

13. **Please find below link to register your firm on Purchase Portal. Without completing registration process on portal can't submit offer.**

First of all register your firm on shared link so can send inquiry through portal only.

Plot No. 35, Nr. Indira Bridge, Ahmedabad-Gandhinagar Highway, Village: Bhat, Dist.:Gandhinagar, PIN 382428

Tel. No. (+91-79) 23969055 – 58, Fax No. (+91-79) 23969059

Website: www.amul.com

AmulFed Dairy

A UNIT OF GUJARAT CO-OPERATIVE MILK MARKETING FEDERATION LIMITED

(Previously Known as Mother Dairy, Gandhinagar)

Interested bidders have to register your firm in our Purchase portal.

Website for our portal is as >>>: <http://afdpurchase.amul.in/>

Click Below links for Guidelines :

1. [Guide for VRF - MANUFACTURERS](#)

14. **Eligibility criteria: Must have executed similar type of order in last 5 year. Share credentials of the same.**
15. **Once registration process completes, we invite vendor to submit offer. Vendors need to submit technical first only after technical clearance you will be able to submit commercial figures.**

We are an ISO 9001: 2015, ISO 14001:2015, ISO 22000:2018, ISO 50001:2018 and ISO 45001:2018 company; we follow sustainable eco-friendly processes in our organization and expect the same to be followed at your end. We emphasis on energy efficient system and utilization of renewable energy systems in eco-friendly and sustainable way.

Note: If required please visit premises with prior confirmation before quote. Please arrange visit between 2:00 P.M. to 5:00 P.M. in working day.

: We may go for reverse auction/negotiation. If required we may ask for PBG.

: Must have valid licence as per CEIG.

Mail id as mentioned below.

Shri Hardik Gajjar : hardik.gajjar@amul.coop

Shri Bharat Naik : bharat.naik@amul.coop

Shri Gaurav : gaurav.desai@amul.coop

Yours Faithfully,

For AmulFed Dairy,

Purchase Depart.



(Previously Known as Mother Dairy, Gandhinagar)

LAYING, INSTALLATION, TERMINATION AND TESTING OF CABLE AT PACKAGING FILM PLANT, SECTOR-25, GANDHINAGAR.

Under Ground Cable Laying procedure:

- A trench of about 1 to 1.5 meters deep and 0.6m wide is dug (Manual) for HT cable and for LT cable width is based on cable qty.
- Then the trench is covered with a 10 cm thick layer of fine sand.
- The cable is laid over the sand bed. The sand bed protects the cable from the moisture from the ground.
- Then the laid cable is again covered with a layer of sand of about 10 cm thick.
- When multiple cables are to be laid in the same trench, a horizontal or vertical spacing of about 30 cm is provided to reduce the effect of mutual heating. Spacing between the cables also ensures a fault occurring on one cable does not damage the adjacent cable.
- The trench is then covered with Suitable size min 100 mm /cable RCC half Round and brick partition between cable to protect the cable from mechanical injury.
- Mark cable number at different interval and both the cable ends.
- RCC Route Markers are required at interval of 15 meter. (2.5 feet height*1 feet width*100mm thick RCC ROUTE marker with embossing as per requirement with yellow color for entire marker and black color letter)

Cable Laying -Pre laid cable Tray:

- Pre laid cable tray are available in field and vendor has to lay cable in cable tray with all safety measures.
- Arrange, Tightening all cables with cable tie/flat strip.
- Mark cable number at different interval and both the cable ends.

Cable Laying -Pre laid Hume Pipes:

- Pre-Laid Hume pipes are available in filed and vendor has to lay cable in pre laid hume without damaging cable insulation.
- Arrange, Tightening all cables with cable tie/flat strip.
- Mark cable number at different interval and both the cable ends.

Cable Termination:

- All Termination, cable joint materials are supplied by AmulFed dairy. Bidder has to consider installation and testing only.
- All Work should be on JMS based
- 10% contingency to be consider as we have to use old cable also.

AmulFed Dairy

A UNIT OF GUJARAT CO-OPERATIVE MILK MARKETING FEDERATION LIMITED

SR NO.	DESCRIPTION LT Cables (Previously Known as Mother Dairy, Gandhinagar)	TOTAL	UNDER	HUME	CABLE TERMINATION
		QTY.	GROUN D	PIPE/CABLE TRENCH/CABLE TRAY	
			QTY	QTY	NOS
1	3.5C*400 mm2 AL Armored Cable	2400	1000	1400	50
2	3.5C*240 mm2 AL Armored Cable	850	400	450	16
3	3.5C*185 mm2 AL Armored Cable	400	160	240	8
4	3.5C*120 mm2 AL Armored Cable	280	100	180	4
5	4C*240 mm2 CU Flexible Cable	500		500	26
6	4C*120 mm2 CU Flexible Cable	520		520	26
7	4C*70 mm2 CU Flexible Cable	150		150	6
8	4C*2.5 mm2 CU Flexible Cable	500		500	20
9	4C*1.5 mm2 CU Flexible Cable	500		500	20
10	4C*35 mm2 CU Armored Cable	160	10	150	4
11	4C*16 mm2 CU Armored Cable	510	10	500	22
12	4C*6 mm2 CU Armored Cable	510	10	500	20
13	4C*2.5 mm2 CU Armored Cable	260	10	250	20
14	4C*1.5 mm2 CU Armored Cable	260	10	250	20

- HT-CABLE 11 KV

SR NO.	DESCRIPTION HT Cable	QTY.	METHOD	END TERMINATION	STRAIGHT JOINT
				UNIT-NOS	UNIT-NOS
1	CABLE 11KV, 3 C * 240 SQMM, XLPE, AL ARMOURED	660	UNDERGROUND	10	2

Old cables to be used.

Rates must be inclusive of all. To & fro traveling, lodging/boarding etc.

Interested vendors request to please visit premises to exactly understand our requirement.

AmulFed Dairy

A UNIT OF GUJARAT CO-OPERATIVE MILK MARKETING FEDERATION LIMITED

(Previously Known as Mother Dairy, Gandhinagar)
On Letter Head of Vendor / Customer.

To,
General Manager
AmulFed Dairy (A Unit of GCMMF Ltd.)
Village:- Bhat,
Near Indira Bridge,
Gandhinagar-382 428

Dear Sir,

Sub : Fund Transfer Payments.

I/we request and authorise you to effect Fund Transfer Payment to my / our Bank account as per the details given below (Please map our account in your SAP):

Vendor Name:- : _____
Vendor Code : _____
Bank Account Name : _____
Bank Account Number : _____
Branch Name & Address of Bank: _____

Email Id : _____
Permanent A/c Number (PAN) : _____
Name of the Auth signatory : _____
Contact Person : _____
Contact Number : _____
IFSC code : _____
MICR Code : _____
Type of Account : Savings / Current / Cash Credit

I, hereby declare that the particulars given above are correct. If the transaction is delayed or not effected at all for reasons of incomplete or incorrect information, I would not hold the user institution responsible. I hereby authorise Bank (as mentioned above) to credit my above mentioned account with the amount of instalment and I agree to discharge the responsibility expected of me as a participant under the scheme.

Date: _____

Signature of Account Holder (s)

- Mandatory fields -cannot be left blank.
 - Kindly attach a blank cancelled cheque with this mandate form.

Bankers Attestion -

CERTIFIED THAT THE PARTICULARS FURNISHED ABOVE ARE CORRECT AS PER OUR RECORDS.

BANK STAMP

DATE : _____

SIGNATUR E OF BANK OFFICIAL

Plot No. 35, Nr. Indira Bridge, Ahmedabad-Gandhinagar Highway, Village: Bhat, Dist.:Gandhinagar, PIN 382428
Tel. No. (+91-79) 23969055 – 58, Fax No. (+91-79) 23969059
Website: www.amul.com